



**Central Purchasing  
213 South Oliver Drive  
Aztec, New Mexico 87410  
(505) 334-4551**

**Bid No. 19-20-14, Construction of Valley Fire Station #3**

**Fire Department**

**ADDENDUM #3**

**April 8, 2020**

**CHANGES / ADDITIONAL INFORMATION TO THE BID SPECIFICATIONS AS  
FOLLOWS:**

- Changes and clarification to the bid specifications have been made pursuant to the attached addendum sheet as provided by Rodahl & Hummell Architecture (1 page).

**Plan Holders List:**

Bidders are reminded that in order to obtain the most current and up to date listing of plan holders, you are encouraged to visit the County's Website at [www.sjcounty.net](http://www.sjcounty.net) (under Quicklinks, choose 'Current Bids/Proposals Page').

**PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID  
OFFER PAGE.**

Addendum #3  
**San Juan County - Valley Fire Station #3**

Rodahl & Hummell Architecture  
609 N. Dustin Avenue  
Farmington, NM 87401  
(505) 326-6442

April 8, 2020

---

This addendum takes precedence over work shown on the Plans and described in the Specifications and shall become a part of the Contract Documents. All work not specifically noted as changed or modified shall be furnished and installed as shown on original Drawings and as outlined in the original specifications.

- Item #1: Specification Section 13 3419. 1.3. - B. Delete "weather tightness warranty".
- Item #2: Specification Section 13 3419. Delete Subsection 2.3. - D.
- Item #3: Specification Section 08 3613. 2.1. - A.1. Change Door Model to 3242 Ribbed Steel Pan Door.
- Item #4: Sheet A1. Ceiling at showers shall be W.R. Gypsum Board painted.
- Item #5: Sheet A1. West wall of Office 105 shall be 6" steel studs.
- Item #6: Sheet A1. Wall Types - 'D' - Extend to 1'-0" above ceiling.
- Item #7: Sheets A1 and A3. Wall Type 'A' - Studs and gypsum board and R-13 goes to roof deck. Apparatus Bay walls receive no batt insulation except at "F" wall.

End of Addendum #3

APPROVED SUBSTITUTIONS:

The following materials/manufacturers have been approved for use in lieu of those specified in the Contract Documents.

Specification Section 13 3419 - Metallic Building Systems  
- Metallic Tuffcast Insulated Panel