



Central Purchasing
213 South Oliver Drive
Aztec, New Mexico 87410
(505) 334-4551

BID No. 22-23-23, McGee Park Lift Station

**ADDENDUM #2
March 21, 2023**

CLARIFICATION / ADDITIONAL INFORMATION FOR BID SPECIFICATIONS AS FOLLOWS:

- Changes and clarification to the bid specifications have been made pursuant to the attached addendum sheet as provided by Cheney Walters Echols (1 page).

Plan Holders List:

Bidders are reminded that in order to obtain the most current and up to date listing of plan holders, you are encouraged to visit the County's Website at www.sjcounty.net.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE OFFER PAGE.

**McGee Park Lift Station
Addendum No. 2**

1. Note 15-Sheet 3/4-Disregard Note 15, the existing Lift Station is to remain in service as the new Lift Station is being constructed.
2. Drawing E101-The Contractor shall install a new raceway from the existing Panel B to the new Lift Station. This allows putting the new Lift Station into operation and then taking the existing Lift Station out of service. This raceway can include a conduit and wiring to provide power to the outdoor light and/or wiring to provide same power.
3. Drawing E101-Note 5-Put light pole receptacle (CKT7) on either CKT17 or CKT18.
4. Out door light-Provide a single head light as per Drawing E501 under the Lighting Fixture Schedule.