



**Central Purchasing
213 South Oliver Drive
Aztec, New Mexico 87410
(505) 334-4551**

BID No. 23-24-25 County Road 350 Metal Bridge Rail Surface Preparation and Coating

**ADDENDUM #2
May 7, 2024**

ADDITIONAL INFORMATION / CLARIFICATION FOR BID SPECIFICATIONS AS FOLLOWS:

Question: Is the existing paint lead-based?

Answer: The existing paint is not lead-based.

Question: What are the Environmental requirements for sandblasting and painting above a river?

Answer: According to the New Mexico Environmental Department, the New Mexico Administrative Code 20.6.2.2201 states that "Disposal of Refuse: No person shall dispose of any refuse in a natural watercourse or in a location and manner where there is reasonable probability that the refuse will be moved into a natural watercourse by leaching or otherwise. Solids diverted from the stream and returned thereto are not subject to abatement under this Section." Section 547: Safety and Environmental Requirements for Painting Operations in the bid documents includes references. Since no specific method is mentioned, the contractor is required to choose a method that will ensure that no sandblasting material, paint chips, etc. enter the river or land adjacent to the river.

Plan Holders List:

Bidders are reminded that in order to obtain the most current and up to date listing of plan holders, you are encouraged to visit the County's Website at www.sjcounty.net.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE OFFER PAGE.